

Monthly CURSORY INSPECTION

Parish: Assumption Str. Type: COSLAB
Str. # 61042320104611 Recall # 051440 Route: LA 70
Bridge Name/Feature Crossed: Bayou Choupique

Approaches:
Roadway:
Deck:
Bearings: N/A
Stringers: N/A
Girders (Conc./Steel): N/A
Piling:
Caps/Piers:
Backwalls:
Wingwalls: N/A
Footings: N/A
Waterway:
Embankment (Scour):
Conc. Spall/Cracks:

√ - If element of structure was inspected

N/A - If element does not apply to structure

Were Pictures Taken: YES or NO

Any changes noted? If so what? A Visual inspection was performed as well as measurements taken on both sides of structure with a transit level. There were no changes when compared to previous inspections.

Inspected By: Brandon McGruder & Billy Baltantz
Date: 8/20/15

Bayou Choupique

Date 8/20/15

TBM	10.0 ft
BS	2.16
HI	

Bent No.		BS	Elev
1	L	1.82	
	R	1.80	
2	L	1.77	
	R	1.75	
3	L	1.72	
	R	1.74	
4	L	1.74	
	R	1.77	
5	L	1.79	
	R	1.80	